



AQUA PRO-TECH LABORATORIES
 Certified Environmental Testing

Client: Supertots I Education Center
 167 Sterling Ave
 Jersey City, NJ 07304

APL Order ID Number: 1040894
 Collected : 04/20/2021 7:00
 Received: 04/20/2021

Contact:
 Client Project: Supertots II Education Center

Contact: 04/28/2021 10:08
 Customer Service Rep: Tony Tudda

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
1040894-01	Drinking Water	Class 1						
Total Metals								
Copper	EPA 200.8	4/22/21 15:50	4/22/21 15:50	0.118			0.00200	mg/L
Lead	EPA 200.8	4/22/21 15:50	4/22/21 15:50	< 0.00200	U		0.00200	mg/L
1040894-02	Drinking Water	Class 2						
Total Metals								
Copper	EPA 200.8	4/22/21 15:54	4/22/21 15:54	0.133			0.00200	mg/L
Lead	EPA 200.8	4/22/21 15:54	4/22/21 15:54	< 0.00200	U		0.00200	mg/L
1040894-03	Drinking Water	Class 3						
Total Metals								
Copper	EPA 200.8	4/22/21 15:59	4/22/21 15:59	0.124			0.00200	mg/L
Lead	EPA 200.8	4/22/21 15:59	4/22/21 15:59	< 0.00200	U		0.00200	mg/L

FootNotes

RL - Reporting limit
 MDL - Minimum detection limit
 ND, U - Indicates compound analyzed for but not detected
 J - Indicates estimated value

B - Indicates compound found in associated blank
 E - Concentration exceeds highest calibration standard
 D - Indicates result is based on a dilution
 P - Greater than 25% diff. between 2 GC columns.

Brian Wood
 Laboratory Director



AQUA PRO-TECH LABORATORIES
 Certified Environmental Testing

Client: Supertots I Education Center
 158 Sterling Ave
 Jersey City, NJ 07304

APL Order ID Number: 1040893
 Collected: 04/20/2021 6:55
 Received: 04/20/2021

Contact:
 Client Project: Supertots I Education Center

Contact: 04/27/2021 12:24
 Customer Service Rep: Tony Tudda

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
1040893-01	Drinking Water	Class 1						
Total Metals								
Copper	EPA 200.8	4/22/21 18:55	4/22/21 18:55	0.0996			0.00200	mg/L
Lead	EPA 200.8	4/22/21 18:55	4/22/21 18:55	< 0.00200	U		0.00200	mg/L
1040893-02	Drinking Water	Class 2						
Total Metals								
Copper	EPA 200.8	4/22/21 18:59	4/22/21 18:59	0.122			0.00200	mg/L
Lead	EPA 200.8	4/22/21 18:59	4/22/21 18:59	< 0.00200	U		0.00200	mg/L

FootNotes

RL - Reporting limit
 MDL - Minimum detection limit
 ND, U - Indicates compound analyzed for but not detected
 J - Indicates estimated value

B - Indicates compound found in associated blank
 E - Concentration exceeds highest calibration standard
 D - Indicates result is based on a dilution
 P - Greater than 25% diff. between 2 GC columns.

Brian Wood
 Laboratory Director